A New Binary Inductive Divider Comparator System for Measuring High-Voltage Thermal Converters

Joseph R. Kinard, Senior Member, IEEE, Thomas E. Lipe, Member, IEEE, and Svetlana Avramov-Zamurovic

Abstract—National Measurement Institutes have traditionally used bootstrapping or build-up techniques to determine the ac-dc difference of high-voltage thermal converters (HVTCs) in terms of the ac-dc difference of lower-voltage converters. We describe a method of determining the ac-dc difference of HVTCs that is independent of the build-up process. A description of the system and technique is given and preliminary data is presented.

Index Terms—AC-DC difference, high-voltage thermal converters (HVTCs), inductive divider, thermal converter, thermal voltage converters (TVC).

I. INTRODUCTION

'IGH-VOLTAGE thermal converters (HVTCs) are used as standards of ac-dc difference and for the measurement and calibration of ac voltage up to 1000 V and 100 kHz [1]. A build-up or scaling procedure is generally employed to determine the ac-dc differences of these devices. In the build-up process (shown in Fig. 1) the ac-dc difference of an HVTC is determined by comparison against a thermal converter of a lower voltage rating. If the ac-dc difference of the higher-range HVTC is independent of voltage level, this comparison will provide the ac-dc difference of the higher-range HVTC, to within the measurement uncertainty. However, the ac-dc difference of the multiplying resistors used in HVTCs may vary as a function of input voltage level, creating significant errors in the build-up process. Formal and informal international intercomparisons of HVTCs have revealed variations among the participant laboratories [2], [3]. Therefore, some National Measurement Institutes (NMIs) are developing calibration procedures that are independent of the build-up process [4]–[6]. In this paper, we report an independent method for determining the ac-dc differences of an HVTC based on a binary inductive voltage divider (BIVD) [7]. We plan to use this independent approach in addition to the traditional build-up method to maintain the quality of the National Institute of Standards and Technology (NIST) HVTCs.

II. BIVD CONSTRUCTION AND CALIBRATION

The BIVD consists of 240 turns of 0.52 mm² twisted-pair wire wound around a high permeability core of 4.2 cm² cross-sectional area, connected to form a center-tapped divider. This winding technique provides good symmetry and a well-defined

Manuscript received May 29, 2001; revised August 5, 2002.

Digital Object Identifier 10.1109/TIM.2002.807794




Fig. 1. Build-up diagram for characterizing HVTCs, beginning with the primary standards at 5 to 10 V and continuing up to 1 kV. The BIVD comparator is intended to address the process indicated by the vertical arrows.

TABLE I CENTER-TAP ERROR (PARTS IN 10^6) of the BIVD as a Function of the Applied Voltage and Frequency. The Measurement Uncertainty is Estimated to be Less Than 0.5×10^{-6}

Frequency (kHz)	Voltage 100 V	Voltage 50 V	
1	0.1	0.1	
10	0.1	0.1	
20	0.6	0.5	

center tap ratio. There are two layers of windings with an intermediate layer of a glass tape to provide a greater distance between turns and thus reduce the capacitance of the transformer. The transformer is enclosed in a shielded box with type-874 connectors. The BIVD is designed to operate at 1000 V up to 50-kHz and to present impedances of less than 200 k at frequencies up to 50 kHz.

The accuracy of the center tap of the BIVD was tested in a bridge configuration against a decade inductive voltage divider set to the ratio 0.5. Since the BIVD is used in TVC measurements with one side of the input grounded, the bridge voltage source was grounded and an isolation transformer was used to allow the detector to be grounded as well. The tests were performed by interchanging the input leads on the dividers. The test results are summarized in Table I. The errors in the BIVD are very small compared to the uncertainties of the HVTC build-up process.

III. BIVD COMPARATOR SYSTEM

The comparator system compares the ac-dc differences of two thermal voltage converters (TVCs) to the ratio of a BIVD (although the system is intended for use with HVTCs, TVCs of any voltage ranges may be used, as long as the ranges are roughly 2:1). The comparison requires that the BIVD ratio and the ratio of two high-voltage dc sources be known. The two HVTCs measure the rms voltages of two high-voltage ac sources in terms of the dc sources. The ratio of the ac sources is also determined

J. R. Kinard and T. E. Lipe are with the Electricity Division, National Institute of Standards and Technology (NIST), Gaithersburg, MD 20899-0001 USA (e-mail: joseph.kinard@nist.gov).

S. Avramov-Zamurovic is with the Weapons and System Engineering Department, U.S. Naval Academy, Annapolis, MD 21402 USA.

maintaining the data needed, and c including suggestions for reducing	ection of information is estimated to ompleting and reviewing the collect this burden, to Washington Headqu ald be aware that notwithstanding an OMB control number.	tion of information. Send commentarters Services, Directorate for Inf	ts regarding this burden estimate formation Operations and Reports	or any other aspect of the s, 1215 Jefferson Davis	his collection of information, Highway, Suite 1204, Arlington	
1. REPORT DATE AUG 2002		2. REPORT TYPE		3. DATES COVE 00-00-2002	ERED 2 to 00-00-2002	
4. TITLE AND SUBTITLE				5a. CONTRACT NUMBER		
A New Binary Inductive Divider Comparator System for High-Voltage Thermal Converters			Measuring	5b. GRANT NUMBER		
				5c. PROGRAM ELEMENT NUMBER		
6. AUTHOR(S)				5d. PROJECT NUMBER 5e. TASK NUMBER		
				5f. WORK UNIT NUMBER		
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) United States Naval Academy, Department of Weapons and S Engineering, Annapolis, MD, 21402			nd Systems	8. PERFORMING ORGANIZATION REPORT NUMBER		
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)		
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)		
12. DISTRIBUTION/AVAIL Approved for publ	ABILITY STATEMENT	ion unlimited				
13. SUPPLEMENTARY NO	TES					
determine the ac-d of lower-voltage co	nent Institutes have c difference of high- nverters. We descri build-up process. A	-voltage thermal co be a method of det	onverters (HVTCs) ermining the ac-de) in terms of c difference (the ac-dc difference of HVTCs that is	
15. SUBJECT TERMS						
16. SECURITY CLASSIFIC	ATION OF:		17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON	
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified	Same as Report (SAR)	5	RESI ONSIDLE FERSUN	

Report Documentation Page

Form Approved OMB No. 0704-0188




Fig. 2. Schematic of BIVD comparator system.




Fig. 3. Interior view of the BIVD comparator enclosure.

in terms of the ratio of the BIVD by the use of two high-performance digital voltmeters (DVMs) that are used solely as transfer instruments. The calibration of the DVMs is therefore not required for the measurement process, as the process relies only on the linearity of the voltmeters over a limited voltage range.

A schematic of the comparator system is shown in Fig. 2 and a picture in Fig. 3. A previous prototype of the comparator system [8] featured eight relays spread out across a bench. In the new version of the BIVD comparator system, the eight relays are contained in a shielded enclosure, along with the inductive divider itself.

The measurement sequence is as follows.

1) The two HVTCs are connected simultaneously to the high-voltage (TVC $_H$) and low-voltage (TVC $_L$) dc sources while the DVMs are connected to the top of the BIVD (DVM $_H$) and its center tap (DVM $_L$). The BIVD voltage is supplied by an ac source. The two HVTC outputs are monitored by nanovoltmeters (nVM $_H$ and nVM $_L$). The circuit diagram for this measurement phase

- is shown in Fig. 4. All system grounds are actually terminated at the ac source supplying the BIVD.
- 2) After the nanovoltmeters and high-voltage DVMs are read, relays R_1 , R_2 , R_3 , and R_4 are switched so that ac voltage is supplied to the HVTCs and the DVMs are connected to the high- and low-voltage ac sources. In this configuration, the ratios of the high- and low-voltage ac voltages are determined in terms of the BIVD center tap ratio. A schematic of this configuration is shown in Fig. 5. While the relays are in these positions, the polarities of the dc voltages are reversed at the sources.
- 3) After the nanovoltmeters and high-voltage DVMs are read, relays R₁, R₂, R₃, and R₄ are returned to their initial positions (Fig. 4). The measurement proceeds as in Step 1, except that the dc voltage is of the opposite polarity. Steps 1, 2, and 3 determine the ratio of the ac sources in terms of the ratio of the dc sources (which are generally more stable) and also determine the ac-dc differences of the two HVTCs.
- 4) After repeated cycles of the measurements discussed in Steps 1–3, relays R₅ and R₆ are closed to connect both DVMs to the high-voltage dc source, as shown in Fig. 6. DVM readings are taken while both polarities of dc voltage are applied to the DVMs. Relays R₇ and R₈ are then switched to connect both DVMs to the low-voltage dc source and readings are taken while both polarities of dc voltage are applied to the DVMs. This procedure determines the departure from the nominal ratio of the DVMs.

Neglecting small second-order quantities, the relationship between the ac-dc differences of the higher voltage converter, δ_H and the lower voltage converter, δ_L , may be given in the form

$$\delta_H - \delta_L = \Delta ratio_{ac} - \Delta ratio_{dc} - \delta_H^m + \delta_L^m. \tag{1}$$

In (1), $\Delta ratio_{ac}$ is the departure of the ac from nominal ratio as determined by the BIVD, satisfying the equation

$$\frac{ac_H}{ac_L} = 2\left(1 + \Delta ratio_{ac}\right)$$

where ac_H is the average voltage supplied by the high-voltage ac source, as determined by the high-voltage DVM and ac_L is the average voltage supplied by the low-voltage ac source, as




Fig. 4. Circuit diagram of the comparator system while dc voltage is applied to the thermal converters. DVM_H and DVM_L are connected to the BIVD.




Fig. 5. Circuit diagram of the comparator system while ac voltage is supplied to the thermal converters. DVM_H and DVM_L are also connected to the ac sources.




Fig. 6. Circuit diagram of the comparator system with the DVMs connected to the high-voltage dc sources. When the DVMs are connected to the low-voltage dc source, R_7 and R_8 are in the normally open position.

TABLE II PRELIMINARY ESTIMATE OF BIVD UNCERTAINTIES IN $\mu \text{V/V}$

Type A component	3.3
Dc measurement	1.2
BIVD ratio	1.2
Loading	1.2
RSS	3.9
Expanded uncertainty (k = 2)	7.8

determined by the low-voltage DVM in measurement step 2.

Similarly, $\Delta ratio_{dc}$ denotes the departure of dc from nominal ratio, satisfying the equation

$$\frac{dc_H}{dc_L} = 2\left(1 + \Delta ratio_{dc}\right)$$

where dc_H is the average value of both polarities of the dc voltage supplied by the high-voltage dc source and dc_L is the average value of both polarities of the dc voltage supplied by the low-voltage dc source, as determined in measurement step 4. In addition, δ_H^m is defined by $\delta_H^m = (E_{ac} - E_{dc})/(n_H E_{dc})$,

Test (High)	Test TVC	Standard	Standard TVC	δ From	δ From	δ From	δ From
	Range	(Low)	Range	Build-up	BIVD	Build-up	BIVD
TVC	V	TVC	V	10 kHz		20 kHz	
F ₇ 600-F ₇ 2	600	F ₁ 300-FB	300	-1.3 ± 10.4	-4.3 ± 7.8	-6.0 ± 11.0	-9.2 ± 7.8
				20 kHz		50 kHz	
F-200-F-2	200	F.100-FB	100	-0.7 ± 7.7	+2.1 + 7.8	-2.8 + 9.0	-0.7 ± 7.8

TABLE III COMPARISON BETWEEN RESULTS (δ) Obtained From the Traditional Build-up Process and Results Obtained Using the BIVD Comparator System in μ V/V. Uncertainties are for k=2

where E_{ac} is the high-voltage TVC output with ac applied, E_{dc} the output of this TVC with dc applied and n_H the TVC response characteristic. Similarly, δ_L^m is defined by $\delta_L^m = (E_{ac} - E_{dc})/(n_L E_{dc})$ where E_{ac} is the low-voltage TVC output with ac applied, E_{dc} the output of this TVC with dc applied and n_L the TVC response characteristic.

IV. LOADING COMPENSATION

An error in the BIVD ratio of about 10^{-4} at 20 kHz results from the loading at the center tap due to the impedance of the system connections and DVM input. To compensate for this error, a simple RC network was installed between the BIVD top high terminal and the center tap high terminal. The appropriate compensation capacitance was estimated by assembling a bridge circuit in order to balance the loading. The loading error was reduced to 10^{-6} using a network with about 700-pF in parallel with 1 M. Other measurement frequencies require different values of RC.

V. RESULTS

Table II gives the contributions to the estimated uncertainty for the BIVD comparator system. Table III presents data taken with the BIVD system compared to the ac-dc differences of several HVTCs predicted from build-up measurements. The BIVD results compare favorably with the results from the build-up process, increasing our confidence in both the traditional build-up process and in the design and construction of the NIST high-voltage resistors.

VI. CONCLUSIONS AND FUTURE PLANS

We have demonstrated a comparator system for determining the ac-dc difference of HVTCs independent of the traditional build-up process. Preliminary data show that results from the BIVD comparator are in good agreement with those from the voltage build-up process and provide an independent confirmation of the efficacy of the build-up technique. Future plans include extending the applied voltage to 1000 V and extending the measurement frequency to higher values at these voltages.

ACKNOWLEDGMENT

The authors would like to thank Mr. R. Palm of the Electricity Division of NIST for constructing the BIVD comparator system enclosure.

REFERENCES

- D.-X. Huang, T. E. Lipe, J. R. Kinard, and C. B. Childers, "AC-DC difference characteristics of high-voltage thermal converters," *IEEE Trans. Instrum. Meas.*, vol. 44, pp. 387–390, Apr. 1995.
- [2] J. P. M. de Vreede, "CCE intercomparison of ac-dc transfer standards," IEEE Trans. Instrum. Meas., vol. 42, pp. 99–108, Apr. 1993.
- [3] A. Poletaeff, "EUROMET project number 266—Draft report," in EU-ROMET AC-DC Transfer Experts Meeting, Bern, Switzerland, 1997.
- [4] P. Simonson and K.-E. Rydlar, "Level dependence of ac-dc transfer devices," *IEEE Trans. Instrum. Meas.*, vol. 48, pp. 395–398, Apr. 1999.
- [5] U. Pogliano, G. C. Bosco, and V. D'Elia, "Measurement system for the voltage dependence of high-voltage ac-dc thermal converters," *IEEE Trans. Instrum. Meas.*, vol. 48, pp. 399–403, Apr. 1999.
- [6] U. Pogliano, "An electrometric method for precise ac-dc transfer measurements," in CPEM Dig., Boulder, CO, June 1, 1994, pp. 363–363.
- [7] S. Avramov-Zamurovic, G. N. Stenbakken, A. D. Koffman, and N. M. Oldham, "Binary versus decade inductive voltage divider comparison and error decomposition," *IEEE Trans. Instrum. Meas.*, vol. 44, pp. 904–908, Aug. 1995.
- [8] J. R. Kinard, T. E. Lipe, C. B. Childers, and S. Avramov-Zamurovic, "Comparison of high voltage thermal converter scaling to a binary inductive voltage divider," in *CPEM Dig.*, Washington, D.C., 1998, pp. 381–382.



Joseph R. Kinard (S'69-M'71-SM'80) was born in West Palm Beach, FL. He received the B.A. degree in physics from Florida State University, Tallahassee, and the M.S. degree in physics from the University of Massachusetts, Amherst.

From 1963 to 1968, he was with the Electricity Division of the National Bureau of Standards. He was at the Department of Physics, University of Massachusetts, from 1968 to 1971. From 1971 to 1983, he was active in a wide range of electrical measurements at the School of Electrical Engineering, University of

New South Wales, Kensington, Australia. He returned to the Electricity Division at the National Institute of Standards and Technology, Gaithersburg, MD, in 1983, where he works in the area of thermal transfer standards, including the application of new technologies to improve primary and working-standard thermal converters.

Mr. Kinard's work has been recognized with two U.S. Department of Commerce Silver Medals and the R & D 100 Award



Thomas E. Lipe (M'94) was born in Albemarle, NC. He received the B.S. degree in physics from East Carolina University, Greenville, NC, in 1980 and the M.S. degree in physics from The Catholic University of America, Washington, D.C., in 1994.

He joined the Electricity Division of the National Institute of Standards and Technology (then NBS) in 1983, where he was responsible for automating the ac-dc difference calibration systems. His current research interests are in ac-dc difference measurements, ac voltage measurements using cryogenic

techniques, and the design and fabrication of advanced thermal converters.

Svetlana Avramov-Zamurovic received the B.S. and M.S. degrees in electrical engineering from the University of Novi Sad, Novi Sad, Yugoslavia, in 1986 and 1990, respectively, and the Ph.D. degree in electrical engineering from the University of Maryland, College Park, in 1994.

From 1990 to 1994, she was involved in developing a voltage ratio bridge for the NASA Zeno experiment. She was a Guest Researcher at the National Institute of Standards and Technology (NIST) from 1990 to 1994. Currently, she is an Assistant Professor at the United States Naval Academy, Annapolis, MD. Her recent work as a Guest Researcher at NIST involves the development of impedance bridges and measuring techniques.